

TEMPERATURE & HUMIDITY RECORD

MONTH		AUGUST 2024						
LOCATION		PGU KA						
DAY	TIME	A.M			P.M			
		TEMP. (°C)	HUMIDITY (%)	SIGNATURE	TIME	TEMP. (°C)	HUMIDITY (%)	SIGNATURE
1	8.30AM				5.30PM			
2	8.30AM				5.30PM			
3	8.30AM				5.30PM			
4	8.30AM				5.30PM			
5	8.30AM				5.30PM			
6	8.30AM				5.30PM			
7	8.30AM				5.30PM			
8	8.30AM				5.30PM			
9	8.30AM				5.30PM			
10	8.30AM				5.30PM			
11	8.30AM				5.30PM			
12	8.30AM				5.30PM			
13	8.30AM	21.0	59	Jan	5.30PM	22.7	63	Jan
14	8.30AM	22.1	64	Jan	5.30PM	23.2	65	Jan
15	8.30AM	21.9	58	Jan	5.30PM	20.7	67	Jan
16	8.30AM	20.0	63	Jan	5.30PM	21.7	60	Jan
17	8.30AM	20.8	59	Jan	5.30PM	21.0	62	Jan
18	8.30AM	21.8	65	Jan	5.30PM	23.0	70	Jan
19	8.30AM	20.5	75	Jan	5.30PM	21.6	69	Jan
20	8.30AM	22.7	62	Jan	5.30PM	24.0	58	Jan
21	8.30AM	20.5	64	Jan	5.30PM	20.6	60	Jan
22	8.30AM	21.0	62	Jan	5.30PM	21.9	61	Jan
23	8.30AM	20.3	63	Jan	5.30PM	20.8	65	Jan
24	8.30AM	23.4	60	Jan	5.30PM	23.7	58	Jan
25	8.30AM	21.9	61	Jan	5.30PM	22.9	59	Jan
26	8.30AM	20.8	62	Jan	5.30PM	21.6	64	Jan
27	8.30AM	21.0	60	Jan	5.30PM			
28	8.30AM				5.30PM			
29	8.30AM				5.30PM			
30	8.30AM				5.30PM			
31	8.30AM				5.30PM			

STORAGE CONTROL STANDARD PARAMETER

TEMPERATURE TO BE SET BETWEEN 18°C TO 24°C AND RELATIVE HUMIDITY TO BE MAINTAINED NOT TO EXCEED 65%. INDICATE TEMPERATURE OR HUMIDITY BEYOND 24°C OR 65% RESPECTIVELY, READING SHALL BE MONITORED CLOSELY. EPM 3-02, PARA 8.0, PAGE 2 OF 5, TO BE REFERRED.