

**TEMPERATURE & HUMIDITY RECORD**

MONTH	<del>OCTOBER</del> OCTOBER 2021							
LOCATION	BONDED STORE							
DAY	A.M				P.M			
	TIME	TEMP. (°C)	HUMIDITY (%)	SIGNATURE	TIME	TEMP. (°C)	HUMIDITY (%)	SIGNATURE
1	0830	22	52%	[Signature]	1500	19.7	60%	[Signature]
2	WEEKEND	20 °C	60%	[Signature]	1400	20 °C	62%	[Signature]
3	WEEKEND	21 °C	65%	[Signature]	1400	21 °C	68%	[Signature]
4	0830	20.4	73%	[Signature]	1400	22	57%	[Signature]
5	0730	21.3	53%	[Signature]	1400	20	55%	[Signature]
6	0800	22.3	60%	[Signature]	1517	22.3	64%	[Signature]
7	0800	22.5	67%	[Signature]	1400	22.6	66%	[Signature]
8	0710	24.7	72%	[Signature]	1400	23.2	67	[Signature]
9	0700	23.4	69	[Signature]	1400	23.0	66	[Signature]
10	0800	23.9	71	[Signature]	1400	22.1	64	[Signature]
11	0800	23.5°C	68%	[Signature]	1400	22	63	[Signature]
12	0830	23.0 °C	64%	[Signature]	1400	23.0	63	[Signature]
13	0800	20.4°C	67%	[Signature]	1400	21.8	56%	[Signature]
14	0830	23°C	55%	[Signature]	1415	22°C	65%	[Signature]
15	0800	22.5°C	62%	[Signature]	1400	22°C	64%	[Signature]
16	0750	23.5°C	62%	[Signature]	1400	22.0	62%	[Signature]
17	0800	22.5°C	62%	[Signature]	1400	23.0	64%	[Signature]
18	0815	22°C	60%	[Signature]	1430	20.0	60%	[Signature]
19	0830	23.9°C	70%	[Signature]	1500	23.5	66%	[Signature]
20	0830	20.4°C	72%	[Signature]	1400	22.2	64%	[Signature]
21	0800	20 °C	62%	[Signature]	1400	23 °C	69%	[Signature]
22	0755	23.7°C	67%	[Signature]	1405	24°C	65%	[Signature]
23	0800	23°C	68%	[Signature]	1400	21°C	67%	[Signature]
24	0800	21 °C	70%	[Signature]	1400	20 °C	71%	[Signature]
25	0810	20 °C	71%	[Signature]	1400	19 °C	73%	[Signature]
26	0730	22°C	63%	[Signature]	1500	20°C	59%	[Signature]
27	0810	19 °C	70%	[Signature]	1430	22 °C	62%	[Signature]
28	0700	23°C	63%	[Signature]	1430	19°C	60%	[Signature]
29	0800	20 °C	61%	[Signature]	1400	23 °C	69%	[Signature]
30	WEEKEND	22 °C	69%	[Signature]	1400	20 °C	62%	[Signature]
31	WEEKEND	23 °C	67%	[Signature]	1400	23 °C	64%	[Signature]

**STORAGE CONTROL STANDARD PARAMETER**  
 TEMPERATURE TO BE SET BETWEEN 18°C TO 24°C AND RELATIVE HUMIDITY TO BE MAINTAINED BETWEEN 55% AND 75%. INDICATE TEMPERATURE OR HUMIDITY BEYOND 24°C OR 75% RESPECTIVELY, SENIOR MAINTENANCE MANAGER SHALL BE INFORMED IMMEDIATELY AND READING SHALL BE MONITORED CLOSELY. EPM 2-02 TO BE REFERRED.

VERIFIED BY SENIOR MAINTENANCE MANAGER :

NAME	SHUHAIMI B. SHAHROM
DATE	21/10/2021
SIGNATURE	[Signature]