



TEMPERATURE & HUMIDITY RECORD

MONTH		JULY 2024						
LOCATION		APMM TOOL STORE						
DAY	TIME	A.M.			P.M.			
		TEMP. (°C)	HUMIDITY (%)	SIGNATURE	TIME	TEMP. (°C)	HUMIDITY (%)	SIGNATURE
	1 8.30AM				5.30PM			
	2 8.30AM				5.30PM			
	3 8.30AM				5.30PM			
	4 8.30AM				5.30PM			
	5 8.30AM				5.30PM			
	6 8.30AM				5.30PM			
	7 8.30AM				5.30PM			
	8 8.30AM				5.30PM			
	9 8.30AM				5.30PM			
	10 8.30AM				5.30PM			
	11 8.30AM				5.30PM			
	12 8.30AM				5.30PM			
	13 8.30AM				5.30PM			
	14 8.30AM				5.30PM			
	15 8.30AM				5.30PM			
	16 8.30AM				5.30PM			
	17 8.30AM				5.30PM			
	18 8.30AM	19.1°C	59%	BY	5.30PM	20.1°C	52%	BY
	19 8.30AM	22.0°C	68%	BY	5.30PM	18.1°C	63%	BY
	20 8.30AM	WEEKEND			5.30PM	WEEKEND		
	21 8.30AM	WEEKEND			5.30PM	WEEKEND		
	22 8.30AM	23.4°C	67%	BY	5.30PM	19.9°C	70%	BY
	23 8.30AM	21.0°C	65%	BY	5.30PM	21.9°C	71%	BY
	24 8.30AM	20.7°C	60%	BY	5.30PM	23.1°C	69%	BY
	25 8.30AM	20.3°C	70%	BY	5.30PM	21.2°C	68%	BY
	26 8.30AM	22.4°C	67%	BY	5.30PM	19.9°C	67%	BY
	27 8.30AM	WEEKEND			5.30PM	WEEKEND		
	28 8.30AM	WEEKEND			5.30PM	WEEKEND		
	29 8.30AM	21.6°C	56%	BY	5.30PM	22.9°C	61%	BY
	30 8.30AM	20.7°C	61%	BY	5.30PM	20.1°C	57%	BY
	31 8.30AM	19.1°C	57%	BY	5.30PM			

STORAGE CONTROL STANDARD PARAMETER
 TEMPERATURE TO BE SET BETWEEN 18°C TO 24°C AND RELATIVE HUMIDITY TO BE MAINTAINED NOT TO EXCEED 75%. INDICATE TEMPERATURE OR HUMIDITY BEYOND 24°C OR 75% RESPECTIVELY. READING SHALL BE MONITORED CLOSELY. EPM 3-02 TO BE REFERRED.

ATTACHMENT 2 NEW THERMOHYDROMETER AND RECORD