

## TEMPERATURE & HUMIDITY RECORD

MONTH								
LOCATION								
DAY	TIME	A.M			P.M			
		TEMP. (°C)	HUMIDITY (%)	SIGNATURE	TIME	TEMP. (°C)	HUMIDITY (%)	SIGNATURE
1	8.30AM				5.30PM			
2	8.30AM				5.30PM			
3	8.30AM				5.30PM			
4	8.30AM				5.30PM			
5	8.30AM				5.30PM			
6	8.30AM				5.30PM			
7	8.30AM				5.30PM			
8	8.30AM				5.30PM			
9	8.30AM				5.30PM			
10	8.30AM				5.30PM			
11	8.30AM				5.30PM			
12	8.30AM				5.30PM			
13	8.30AM				5.30PM			
14	8.30AM				5.30PM			
15	8.30AM				5.30PM			
16	8.30AM				5.30PM			
17	8.30AM				5.30PM			
18	8.30AM				5.30PM			
19	8.30AM				5.30PM			
20	8.30AM				5.30PM			
21	8.30AM				5.30PM			
22	8.30AM				5.30PM			
23	8.30AM				5.30PM			
24	8.30AM				5.30PM			
25	8.30AM				5.30PM			
26	8.30AM				5.30PM			
27	8.30AM				5.30PM			
28	8.30AM				5.30PM			
29	8.30AM				5.30PM			
30	8.30AM				5.30PM			
31	8.30AM				5.30PM			

**STORAGE CONTROL STANDARD PARAMETER**

MAINTAIN STORAGE TEMPERATURES BETWEEN 18 °C AND 24 °C, WITH RELATIVE HUMIDITY NOT EXCEEDING 75% FOR GENERAL STORAGE, WAREHOUSE AND TOOLSTORE, AND 65% FOR THE WORKSHOP; IF THESE LIMITS ARE EXCEEDED, MONITOR CLOSELY AND REFER TO EPM 3-02 FOR FURTHER DETAILS.

**INSTRUCTIONS FOR FILLING OUT THE GAM/E-026 TEMPERATURE AND HUMIDITY RECORD.**

<b>INDICATION</b>	<b>INSTRUCTION</b>
<b>MONTH</b>	Fill in the month of the record
<b>LOCATION</b>	Fill in the location of the record
<b>DAY</b>	Fill in the day of the record
<b>TIME</b>	Fill in the time of the record
<b>TEMPERATURE</b>	Fill in the temperature reading of the room
<b>HUMIDITY</b>	Fill in the humidity reading in the room
<b>SIGNATURE</b>	The signature of the personnel who perform the check